

RARITAN TOWNSHIP
BOARD OF HEALTH MINUTES

MAY 4, 2017

CALL TO ORDER

The meeting was called to order by Chairman Frank Nagy at 2:00 p.m. at the Municipal Building, One Municipal Drive, Flemington, NJ 08822

MEETING ADVERTISED

The meeting was advertised in the February 28, 2017 issue of the Courier News and posted on the office bulletin board.

ATTENDANCE

In attendance were Board Members Jeannie Geremia, Mark Peters, Rose Sollena and Frank Nagy.

NEW BUSINESS

BLOCK 42, LOT 7.01 – SEPTIC SYSTEM ALTERATION WAIVERS

Motion was made by Mark Peters and seconded by Jeannie Geremia to approve the highest regional water table at 18 inches which is less than the maximum allowed by State Code of 24 inches from the surface. There will still be a minimum of 48 inches of separation from the regional water table and proposed level of infiltration. The Board

also approved the toe of the mound at only 6 feet from the property line instead of the County's requirement of 10 feet. The engineer certified that there are no offsite water issues. The Board approved the distance of 97 feet from the well to the septic system instead of the required 100 feet. The Board is in receipt of the GP25 Permit from the NJ Department of Environmental Protection. This is based on a letter from Robert Vaccarella of the County Health Department dated April 20, 2017.

Roll Call Vote: Jeannie Geremia - yes
 Mark Peters – yes
 Rose Sollena – yes
 Frank Nagy – yes

Motion carried.

ADJOURNMENT

Chairman Frank Nagy asked for a motion to adjourn the meeting.

Motion was made by Jeannie Geremia and seconded by Rose Sollena.

Meeting adjourned at: 2:30 p.m.

Respectfully submitted,

Kristi Gano
Deputy Township Clerk